

Certificate of Product Approval

Certificate Number: 378w

Issue: 01



Eaton Electrical Products Limited

Llantarnam Park
Cwmbran
South Wales
NP44 3AW
United Kingdom

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi Criteria Detector

MAOH850
FXN722
CAPT340
COPOH450
(Refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018
EN 54-7:2018
EN 54-17:2005
CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

Signed for BRE Global Ltd

Verifier

22 July 2022

Date of Issue

22 July 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 378w

Issue: 01

Eaton Electrical Products Limited

Certified Product	Description	LPCB Ref.No.
MAOH850	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (MAB800 bases) - (Menvier) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/01
FXN722	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (FXN720 bases) - (JSB) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/01
CAPT340	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (CAB300 base) – (Cooper) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone Category A2S)	378w/01
COPOH450	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (COPA800 base) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 July 2022

Date of Issue

22 July 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 378w

Issue: 01

Eaton Electrical Products Limited

Certified Product	Description	LPCB Ref.No.
MAOH850	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (MAB800 bases) - (Menvier) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/02
FXN722	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (FXN720 bases) - (JSB) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/02
CAPT340	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (CAB300 base) – (Cooper) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/02
COPOH450	Intelligent Analogue Addressable Category A2S Multisensor Opto/Heat Detector with Short Circuit Isolator (COPA800 base) Notes: 1. Meets the requirements of EN 54-5 and EN 54-7 in the following modes: Mode 2 – Photoelectric/Heat combined together with an alarm output from temperature alone (Category A2S) Mode 3 – Heat Detector alone (Category A2S)	378w/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 July 2022

Date of Issue

22 July 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 378w

Issue: 01

Eaton Electrical Products Limited

Bases

MAB800 (Menvier)
FXN720 (JSB)
CAB300 (Cooper)
COPA800

Single contact standard analogue addressable mounting base
Single contact standard analogue addressable mounting base
Single contact standard analogue addressable mounting base
Single contact standard analogue addressable mounting base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 July 2022

Date of Issue

22 July 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

